


OZONE MEASUREMENT (WITHOUT pH)




ANALOGUE OUTPUT SIGNALS

OUT.CLAMP	OUTPUT	
12 13	1	OZONE 1
14 15	2	OZONE 2 / pH
16 17	3	TEMPERATURE 1/AR.AVERAGE/CONTROLLER 2
18 19	4	TEMPERATURE 2/CONTROLLER 1

ANALYZER - PROBE CONNECTIONS, OZONE AND pH MEASUREMENT

INPUT CLAMP	MOZ66	PROBE		
20	INPUT 1	20	OZONE 1	PROBE SPR42 , PK41
21	INPUT 1	19	OZONE 1	
22	INPUT 2	18	pH	
23	INPUT 2	17	pH	

OZONE AND pH MEASUREMENT (TEMPERATURE USED FOR COMPENSACION ONLY)



z	GREEN
č	BLACK
b	WHITE
r	RED
me	MAIN ELECTRODE
re	REFERENCE ELECTRODE