

**ANALOGUE OUTPUT SIGNALS**


OUT.CLAMP	OUTPUT	
12 13	1	ClO <sub>2</sub> 1
14 15	2	ClO <sub>2</sub> 2 / pH
16 17	3	AR.AVERAGE/CONTROLLER 2
18 19	4	CONTROLLER 1

**ANALYZER-PROBE CONNECTIONS, CHLORINE DIOXIDE AND pH MEASUREMENT**


INPUT.CLAMP	MPC66	PROBE	
20	INPUT 1	20	ClO <sub>2</sub> 1
21	INPUT 1	19	ClO <sub>2</sub> 1
22	INPUT 2	18	pH
23	INPUT 2	17	pH

PROBE SPR42 , PK41

**CHLORINE DIOXIDE MEASUREMENT (WITHOUT pH)**



**CHLORINE DIOXIDE AND pH MEASUREMENT (TEMPERATURE USED FOR COMPENSATION ONLY)**



z	GREEN
c	BLACK
b	WHITE
r	RED
me	MAIN ELECTRODE
re	REFERENCE ELECTRODE