


### ORP MEASUREMENT




### ANALOGUE OUTPUT SIGNALS

OUT.CLAMP	OUTPUT	
12 13	1	ORP 1
14 15	2	ORP 2 / pH
16 17	3	TEMPERATURE 1/AR.AVERAGE/CONTROLLER 2
18 19	4	TEMPERATURE 2/CONTROLLER 1

### ANALYZER-PROBE CONNECTIONS

INPUT CLAMP	MRP66	PROBE		
20	INPUT 1	20	ORP 1	PROBE 1
21	INPUT 1	19	ORP 1	
24	INPUT 3	18	TEMPERATURE 1	
25	INPUT 3	17	TEMPERATURE 1	
22	INPUT 2	20	ORP 2 / pH	PROBE 2
23	INPUT 2	19	ORP 2 / pH	
26	INPUT 4	18	TEMPERATURE 2	
27	INPUT 4	17	TEMPERATURE 2	
6	CLEANING	17a	CLEANING	PROBE 1,2
7	CLEANING	18a	CLEANING	PROBE 1,2

### ORP/pH AND TEMPERATURE MEASUREMENT



me	MAIN ELECTRODE
re	REFERERENCE ELECTRODE